



Project Update Letter

Date – 04th October 2018
Total Pages - 1

KINGSTON HOLDINGS FZC
Sharjah Airport Free Zone
SHARJAH, U.A.E
Kind Attn : Mr. Muthaia MV

Subject: Project update letter, **UL Project Number** 4788587441.1.1
Product : Empty Enclosure (REXTON Row DB)
Reference : Project Number 4788587441.1.1
Standard : IEC 60529 Ed.2.2
Test Performed : IP41 test (cl. No.13.2 &14.2.1 of IEC 60529 Ed.2.2)
Product Details : Empty Enclosure (Row DB)

Dear Mr. Muthia

This serves to update you on the progress of IP41 test on your empty enclosure (REXTON Row DB). The test on the sample completed successfully as per the standard mentioned above.
Should you have any questions or comments concerning the above, please feel free to contact the undersigned. We look forward to working with you in the future.
Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Sincerely,

Santosh Tripathy
Senior Project Engineer
E-mail: Santosh.Tripathy@ul.com

Reviewed by

Raghunath G
Engineering Leader
E-mail: Raghunath.G@ul.com